


SOPHIA MULTI-ZONE DUCTLESS INVERTER

SPLIT AIR CONDITIONER WITH HEAT PUMP CASSETTE TYPE **OWNER'S MANUAL** INDOOR UNIT

Models: CH-09MSPHCT-230VI CH-12MSPHCT-230VI CH-18MSPHCT-230VI CH-24MSPHCT-230VI CH-36MSPHCT-230VI CH-48MSPHCT-230VI




IMPORTANT NOTE:


- Read this manual carefully before installing or operating your new air conditioning unit. Make sure to save this manual for future reference.
- This manual only describes the installation of outdoor unit. When installing the indoor unit, refer to the installation manual of indoor unit.

If you are using this as a MULTI unit, please refer to the installation & operation manuals that accompany the outdoor unit.

Table of Contents

Owner's Manual






4 Care and Maintenance.

Unit Maintenance .	09
How to Clean the Air Filter .	09
Repairing Refrigerant Leaks	10
Preparation for Periods of Non-use	10

09



Safety Precautions

Thank you for purchasing this air conditioner. This manual will provide you with information on how to operate, maintain, and troubleshoot your air conditioner. Following the instructions will ensure the proper function and extended lifespan of your unit.

Please pay attention to the following signs:



Failure to observe a warning may result in death. The appliance must be installed in accordance with national regulations.



Failure to observe a caution may result in injury or equipment damage.

🛕 WARNING

- Ask an authorized dealer to install this air conditioner. Inappropriate installation may cause water leakage, electric shock, or fire.
- The warranty will be voided if the unit is not installed by professionals.
- If abnormal situation arises (like burning smell), turn off the power supply and call your dealer for instructions to avoid electric shock, fire or injury.
- <u>DO NOT</u> let the indoor unit or the remote control get wet. It may cause electric shock or fire.
- <u>DO NOT</u> insert fingers, rods or other objects into the air inlet or outlet. This may cause injury, since the fan may be rotating at high speeds.
- A warning that the appliance shall be stored in a well-ventilated area where the room size corresponds to the room area as specified for operation.
- Any person who is involved with working on or breaking into a refrigerant circuit should hold a current valid certificate from an industry-accredited assessment authority, which authorises their competence to handle refrigerants safely in accordance with an industry recognised assessment specification.


- Servicing shall only be performed as recommended by the equipment manufacturer. Maintenance and repair requiring the assistance of other skilled personnel shall be carried out under the supervision of the person competent in the use of flammable refrigerants.
- If the supply cord is damaged, it must be replaced by the manufacturer, its service agent or similarly qualified persons in order to avoid a hazard.

- <u>DO NOT</u> touch the air outlet while the swing flap is in motion. Fingers might get caught or the unit may break down.
- **DO NOT** inspect the unit by yourself. Ask an authorized dealer to perform the inspection.
- To prevent product deterioration, do not use the air conditioner for preservation purposes (storage of food, plants, animals, works of art, etc.).
- <u>DO NOT</u> touch the evaporator coils inside the indoor unit. The evaporator coils are sharp and may cause injury.
- <u>DO NOT</u> operate the air conditioner with wet hands. It may cause electric shock.
- <u>DO NOT</u> place items that might be affected by moisture damage under the indoor unit. Condensation can occur at a relative humidity of 80%.
- <u>DO NOT</u> expose heat-producing appliances to cold air or place them under the indoor unit. This may cause incomplete combustion or deformation of the unit due to the heat.
- After long periods of usage, check the indoor unit to see if anything is damaged. If the indoor unit is damaged, it may fall and cause injury.
- If the air conditioner is used together with other heating devices, thoroughly ventilate the room to avoid oxygen deficiency.
- <u>DO NOT</u> climb onto or place objects on top of the outdoor unit.
- <u>DO NOT</u> operate the air conditioner when using fumigant insecticides. The chemicals may become layered with the unit and endanger those who are hypersensitive to chemicals.
- **DO NOT** let children play with the air conditioner.
- **DO NOT** operate the air conditioner in a wet room (e.g. bathroom or laundry room). This can cause electrical shock and cause the product to deteriorate.

- This appliance can be used by children aged from 8 years and above and persons with reduced physical, sensory or mental capabilities or lack of experience and knowledge if they have been given supervision or instruction concerning use of the appliance in a safe way and understand the hazards involved. Children shall not play with the appliance. Cleaning and user maintenance shall not be made by children without supervision.
- The appliance shall be installed in accordance with national wiring regulations.
- The indoor unit must be installed 8.21in/2,5m above floor.
- An all-pole disconnection device which has at least 0.12ft/3mm separation distance in all pole and a residual current device (RCD) with the rating of above 10mA shall be incorporated in the fixed wiring according to the national rule.

Indoor Unit Parts And Major Functions

Indoor Unit Parts And Major Functions



Operating Conditions

Use the system under the following temperatures for safe and effective operation. If the air conditioner is used under different conditions, it may malfunction or become less efficient.

Inverter Split Type

	COOL mode	HEAT mode	DRY mode	
Room Temperature	62°F - 90°F (17°C - 32°C)	32°F - 86°F (0°C - 30°C)	62°F - 90°F (17°C - 32°C)	
Outdoor Temperature	32°F - 122°F 0°C - 50°C		32°F - 122°F (0°C - 50°C)	
	5°F - 122°F (-15°C - 50°C) (For models with low temp. cooling systems.)	5°F - 76°F (-15°C - 24°C)		
	64°F - 129°F (18°C - 54°C) (For special tropical models)	19°F - 75°F -7°C - 24°C	32°F - 140°F (0°C - 60°C) (For special tropical models)	

FOR OUTDOOR UNITS WITH AUXILIARY ELECTRIC HEATER

2

When outside temperature is below 32°F (0°C), we strongly recommend keeping the unit plugged in at all time to ensure smooth ongoing performance.

· Fixed-speed Type

	COOL Mode	HEAT mode	DRY mode	
Indoor Temperature	62°-90°F (17°-32°C)	32°-86°F (O°-30°C)	62°-90°F (17°-32°C)	
Outdoor Temperature	64°-109°F (18°-43°C)		64°-109°F (18°-43°C)	
	19°-109°F (-7°-43°C) (low temperature cooling models)	19°-75°F (-7°-24°C)	64°-129°F (18°-54°C)	
	64°-129°F (18°-54°C) (For special tropical models)		(For special tropical models)	

Features

Default Setting

When the air conditioner restarts after a power failure, it will default to the factory settings (AUTO mode, AUTO fan, 75°F (24°C). This may cause inconsistencies on the remote control and unit panel. Use your remote control to update the status.

Auto-Restart (some models)

In case of power failure, the system will immediately stop. When power returns, the Operation light on the indoor unit will flash. To restart the unit, press the **ON/OFF** button on the remote control. If the system has an auto restart function, the unit will restart using the same settings.

Louver Angle Memory Function (Optional)


Some models are designed with a louver angle memory function. When the unit restarts after a power failure, the angle of the horizontal louvers will automatically return to the previous position. The angle of the horizontal louver should not be set too small as condensation may form and drip into the machine. To reset the louver, press the manual button, which will reset the horizontal louver settings.

Refrigerant Leak Detection System (some models)


In the event of a refrigerant leak, the LCD screen will display "EC" and the LED indicator light will flash.


Energy Saving Tips

- **<u>DO NOT</u>** set the unit to excessive temperature levels.
- While cooling, close the curtains to avoid direct sunlight.
- Doors and windows should be kept closed to keep cool or warm air in the room.
- <u>DO NOT</u> place objects near the air inlet and outlet of the unit. This will reduce the efficiency of the unit.
- Set a timer and use the built-in SLEEP/ECONOMY mode if applicable.
- If you don't plan to use the unit for a long time, remove the batteries from the remote control.
- Clean the air filter every two weeks. A dirty filter can reduce cooling or heating efficiency.
- Adjust louvers properly and avoid direct airflow.




Closing curtains during heating also helps keep the heat in





Manual Operations

This display panel on the indoor unit can be used to operate the unit in case the remote control has been misplaced or is out of batteries.








Fig. 3.2

- MANUAL button: This button selects the mode in the following order: AUTO, FORCED COOL, OFF.
- FORCED COOL mode: In FORCED COOL mode, the Operation light flashes. The system will then turn to AUTO after it has cooled with a high wind speed for 30 minutes. The remote control will be disabled during this operation.
- OFF mode: When the panel is turned OFF, the unit turns off and the remote control is re-enabled.

Care And Maintenance

Safety Precautions

- Contact an authorized service technician for repair or maintenance. Improper repair and maintenance may cause water leakage, electrical shock, or fire, and may void your warranty.
- <u>DO NOT</u> substitute a blown fuse with a higher or lower amperage rating fuse, as this may cause circuit damage or an electrical fire.
- Make sure the drain hose is set up according to the instructions. Failure to do so could cause leakage and result in personal property damage, fire and electric shock.
- Make sure that all wires are connected properly. Failure to connect wires according to instructions can result in electrical shock or fire.

Unit Maintenance

BEFORE CLEANING OR MAINTENANCE

- Always turn off your air conditioning system and disconnect the power supply before cleaning or maintenance.
- <u>DO NOT</u> use chemicals or chemically treated cloths to clean the unit.
- <u>DO NOT</u> use benzene, paint thinner, polishing powder or other solvents to clean the unit. They can cause the plastic surface to crack or deform.
- <u>DO NOT</u> wash the unit under running water. Doing so causes an electrical hazard.
- <u>DO NOT</u> use water hotter than 104°F (40°C) to clean the front panel. This can cause the panel to become deformed or discolored.
- Clean the unit using a damp, lint-free cloth and neutral detergent. Dry the unit with a dry, lint-free cloth.

How To Clean The Air Filter


The filter prevents dust and other particles from entering the indoor unit. Dust buildup can reduce the efficiency of the air conditioner. For optimum efficiency, clean the air filter every two weeks or more frequently if you live in a dusty area. Replace the filter with a new one if it's heavily clogged and cannot be cleaned.

WARNING: DO NOT REMOVE OR CLEAN THE FILTER BY YOURSELF

Removing and cleaning the filter can be dangerous. Removal and maintenance must be performed by a certified technician.

NOTE: In households with animals, you will have toperiodically wipe down the grille to prevent animal hair blocking airflow.


- 1. Unlock the grille by pushing the two tabs towards the middle simultaneously.
- 2. Unplug the display panel cable from the control box on the main body.






3. Detach the grille from the main unit by holding the grille at a 45° angle, lifting it up slightly and then pulling the grille forward.

NOTE: Some models include an auto-lifting panel function, which allows the grill to move vertically and simplifies the filter cleaning process.




- 4. Remove the air filter.
- 5. Clean the air filter by vacuuming the surface or washing it in warm water with mild detergent.
 - A. If using a vacuum cleaner, the inlet side should face the vacuum.





B. If using water, the inlet side should face down and away from the water stream.





- Rinse the filter with clean water and allow it to air-dry. <u>DO NOT</u> let the filter dry in direct sunlight.
- 7. Reinstall the filter.
- 8. Reinstall the front grille and reconnect the display panel cable to the control box on the main body.

Repairing Refrigerant Leaks

- If the refrigerant leaks, turn off the air conditioner and any combustible heating devices, ventilate the room and call your dealer immediately. Refrigerant is both toxic and flammable. <u>DO NOT</u> use the air conditioner until the leak is repaired.
- When the air conditioner is installed in a small room, measures must be taken to prevent the refrigerant concentration from exceeding the safety limit in the event of refrigerant leakage. Concentrated refrigerant causes a severe health and safety threat.

Refrigerant Leak Detection System (some models)

 In the event of a refrigerant leak, the LCD screen will display "EC" and the LED indicator light will flash.

Preparation For Periods Of Non-Use

Maintenance after Extended Non-Use

- 1. Remove any obstacles blocking the vents of both the indoor and outdoor units.
- 2. Clean the air filter and the front grille of the indoor unit. Reinstall the clean, dry air filter in its original position.
- 3. Turn on the main power switch at least 12 hours prior to operating the unit.

Storing the Unit While Not In Use

- 1. Run the appliance on FAN mode for 12 hours in a warm room to dry it and prevent mold.
- 2. Turn off the appliance and unplug it.
- 3. Clean the air filter according to the instructions in the previous section. Reinstall the clean, dry filter before storing.
- 4. Remove the batteries from the remote control.

Troubleshooting

If one of the following conditions occurs, switch off the power supply immediately and contact your dealer for further assistance.

- The operation light continues to flash rapidly after the unit has been restarted.
- The remote control buttons do not work.
- The unit continually trips fuses or circuit breakers.
- A foreign object or water enters the air conditioner.
- The indoor unit leaks.
- Other abnormal situations.

Common Problems

The following symptoms are not a malfunction and in most situations will not require repairs.

Problem	Possible Causes
Unit does not turn on when	The unit has a 3-minute protection feature that prevents the unit from overloading. The unit cannot be restarted within three minutes of being turned off. Cooling and Heating Models: If the Operation light and PRE-DEF (Pre-heating/
pressing ON/ OFF button	Defrost) indicators are lit up, the outdoor temperature is too cold and the unit's anti-cold wind is activated in order to defrost the unit.
	In Cooling-only Models: If the "Fan Only" indicator is lit up, the outdoor temperature is too cold and the unit's anti-freeze protection is activated in order to defrost the unit.
The unit changes from COOL mode	The unit changes its setting to prevent frost from forming on the unit. Once the temperature increases, the unit will start operating again.
to FAN mode	The set temperature has been reached, at which point the unit turns off the compressor. The unit will resume operating when the temperature fluctuates again.
The indoor unit emits white mist	In humid regions, a large temperature difference between the room's air and the conditioned air can cause white mist.
Both the indoor and outdoor units emit white mist	When the unit restarts in HEAT mode after defrosting, white mist may be emitted due to moisture generated from the defrosting process.
The indoor unit	A squeaking sound is heard when the system is OFF or in COOL mode. The noise is also heard when the drain pump (optional) is in operation.
makes noises	A squeaking sound may occur after running the unit in HEAT mode due to expansion and contraction of the unit's plastic parts.
Both the indoor unit and outdoor	A low hissing sound may occur during operation. This is normal and is caused by refrigerant gas flowing through both the indoor and outdoor units.
unit make noises	A low hissing sound may be heard when the system starts, has just stopped running or is defrosting. This noise is normal and is caused by the refrigerant gas stopping or changing direction.
The outdoor unit makes noises	The unit will make different sounds based on its current operating mode.

Problem	Possible Causes
Dust is emitted from either the indoor or outdoor unit	The unit may accumulate dust during extended periods of non-use, which will be emitted when the unit is turned on. This can be mitigated by covering the unit during long periods of inactivity.
The unit emits a bad odor	The unit may absorb odors from the environment (such as furniture, cooking, cigarettes, etc.) which will be emitted during operations. The unit's filters have become moldy and should be cleaned.
The fan of the outdoor unit does not operate	During operation, the fan speed is controlled to optimize product operation.

Troubleshooting Tips

When troubles occur, please check the following points before contacting a repair company.

Problem	Possible Causes	Solution		
	Power failure	Wait for the power to be restored		
The unit	The power switch is off	Turn on the power		
is not	The fuse is burned out	Replace the fuse		
working	Remote control batteries are dead	Replace the remote control batteries		
	The unit's 3-minute protection has been activated	Wait three minutes after restarting the unit		
	Temperature setting may be higher than the ambient room temperature	Lower the temperature setting		
	The heat exchanger on the indoor or outdoor unit is dirty	Clean the affected heat exchanger		
	The air filter is dirty	Remove the filter and clean it according to instructions		
Poor cooling performance	The air inlet or outlet of either unit is blocked	Turn the unit off, remove the obstruction and turn it back on		
	Doors and windows are open	Make sure that all doors and windows are closed while operating the unit		
	Excessive heat is generated by sunlight	Close windows and curtains during periods of high heat or bright sunshine		
	Low refrigerant due to leak or long-term use	Check for leaks, re-seal if necessary and top off refrigerant		
	There's too much or too little refrigerant in the system	Check for leaks and recharge the system with refrigerant		
The unit starts and	There is air, incompressible gas or foreign material in the refrigeration system.	Evacuate and recharge the system with refrigerant		
stops frequently	System circuit is blocked	Determine which circuit is blocked and replace the malfunctioning piece of equipment		
	The compressor is broken	Replace the compressor		
	The voltage is too high or too low	Install a manostat to regulate the voltage		
	The outdoor temperature is lower than 44°F (7°C)	Check for leaks and recharge the system with refrigerant		
Poor heating performance	Cold air is entering through doors and windows	Make sure that all doors and windows are closed during use		
	Low refrigerant due to leak or long-term use	Check for leaks, re-seal if necessary and top off refrigerant		

· Inverte	er Split Type			
Number	Cause	Operation indicator flashes	Timer indicator	Error Code
1	Indoor EEPROM (Electrically Erasable Programmable Read-Only Memory) error	1	Off	EO
2	Indoor and outdoor unit communication malfunction	2	Off	El
3	Indoor fan speed malfunction	4	Off	E 3
4	Indoor room temperature sensor error	5	Off	E٩
5	Evaporator coil temperature sensor error	6	Off	ES
6	Refrigerant leak detection system malfunction	7	Off	EC
7	Water level alarm malfunction	8	Off	EE
8	Dual indoor unit (twin model only) communication malfunction	9	Off	E8
9	Other twin model malfunction	10	Off	E9
10	Overload protection	1	On	FO
11	Outdoor temperature sensor error	2	On	F¦
12	Outdoor condenser pipe sensor error	3	On	53
13	Discharge air temperature sensor error	4	On	F3
14	Outdoor EEPROM (Electrically Erasable Programmable Read-Only Memory) error	5	On	Fч
15	Outdoor fan speed (DC fan motor only) malfunction	6	On	FS
16	Auto-lifting panel communication error	8	On	۶٦
17	Auto-lifting panel malfunction	9	On	F8
18	Auto-lifting panel is open	10	On	F9
19	Inverter module IPM protection	1	Flash	PO
20	High/Low voltage protection	2	Flash	P:
21	Compressor top overheating protection	3	Flash	59
22	Outdoor low temperature protection	4	Flash	P3
23	Compressor drive error	5	Flash	Рч
24	Mode conflict	6	Flash	PS
25	Compressor low-pressure protection	7	Flash	P6
26	Outdoor IGBT sensor error	8	Flash	P)

· Fixed-speed Type

 Fixed-speed Type O O O O O O O O O O O O O O O O O O O						
Numbe	r Cause	Operation indicator	Timer indicator	Erro Coc	or PRE-DEF le indicato	
1	In-outdoor unit communication checking channel is abnormal	Quick-flash		El	Quick-flash	
2	Room temperature sensor checking channel is abnormal		Quick-flash	53		
3	Evaporator sensor malfunction	Quick-flash		E 3		
4	Condenser sensor malfunction			Ey	Quick-flash	
5	Water pump temperature sensor			ES		Quick-flash
6	Outdoor malfunction	Quick-flash	Quick-flash	E 6	Quick-flash	Quick-flash
7	EEPROM malfunction	Quick-flash	Quick-flash	53		
8	Water level alarm malfunction			E8		Quick-flash
9	DC motor speed out of control		Quick-flash	Еь		Quick-flash
10	Outdoor unit low pressure malfunction	Quick-flash	Quick-flash	Ed	Quick-flash	
11	Auto-lifting panel communication error	Quick-flash		FO	Quick-flash	Quick-flash
12	Auto-lifting panel malfunction		Quick-flash	Fł	Quick-flash	Quick-flash
13	Auto-lifting panel is open		On	53	Quick-flash	Quick-flash
14	Refrigerant leak detection system malfunction	Quick-flash		EC		Quick-flash

The design and specifications are subject to change without prior notice for product improvement.Consult with the sales agency or manufacturer for details.